

CERTIFICATE OF COMPLIANCE

Certificate Number 20160407-R26059
Report Reference R26059-20160407
Issue Date 2016-APRIL-07

Issued to: AL BARRAK AUTOMATIC DOOR FACTORY
PO BOX 10170
MUBARRAZ
AL AHSA 31982 SAUDI ARABIA

This is to certify that
representative samples of

SWINGING-TYPE FIRE DOORS, POSITIVE-PRESSURE
TESTED

A pair of swinging-type fire door assembly of the hollow-
metal steel stiffened type with mineral wool core, rated up to
and including 1 hr.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10C, Positive Pressure of Fire Tests of Door
Assemblies

ANSI/UL 10B, Fire Tests of Door Assemblies

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>





مصنع البراك لأبواب الكراجات

شركة مجموعة البراك للتجارة والصناعة

«شركة ذات مسؤولية محدودة»

DOUBLE HOLLOW METAL DOORS SIZE:

The hollow steel door assembly is intended for openings as indicated in the table below:

Opening Type	Maximum Size, mm (in.)		Hourly Rating, (hr)
	Width	Height	
Standard Pair (active/inactive leaves)	2000 (78-11/16)	2350 (92-1/2)	1



Al-Barrak Group Company for Trade, Industry and Contracting Branch

Factory - Al-Ahsa Industrial City 2257021648

Administration - Al-Ahsa 31982 - Mubarratz PO Box 10170

Tel: 9665866406 – 9665826507 - 966135828509

Fax: 96635870212

barrakgdf@gmail.com

مجموعة البراك للتجارة والصناعة و المقاولات
المصنع - المدينة الصناعية بالأحساء ٢٢٥٧.٢١٦٤٨
الإدارة - الأحساء ٣١٩٨٢ - المبرز ص.ب. ١٠١٧٠
تليفون: ٩٦٦٥٨٢٨٥.٩ - ٩٦٦٥٨٢٦٥.٧ - ٩٦٦٥٨٦٦٤.٦
فاكس: ٩٦٦٣٥٨٧.٢١٢