

CERTIFICATE OF COMPLIANCE

Certificate Number 20180806-R39385
Report Reference R39385-20180727
Issue Date 2018-AUGUST-06

Issued to: AL BARRAK AUTOMATIC DOOR FACTORY
Po Box 10170
Mubarratz
Al Ahsa 31982 SAUDI ARABIA

**This is to certify that
representative samples of**

ROLLING STEEL FIRE DOORS
Model RW18 - 1FR, Insulated Slats Rolling Steel Fire Door,
rated up to and including 1 hr., face mounted to masonry
wall type constructions.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 10B-Fire Tests of Door Assemblies
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

B. Mahlen

Bruce Mahlenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/certifications/>





مصنع البراك لأبواب الكراجات

شركة مجموعة البراك للتجارة والصناعة

«شركة ذات مسؤولية محدودة»

INSULATED SHUTTER DOORS SIZE:

The rolling steel door assembly is intended for openings as indicated in the table below:

Opening Type	Maximum Size, mm (in.)		Hourly Rating, (hr)
	Width	Height	
Model RW18 - 1FR, Insulated Slats Rolling Steel Fire Door.	3657 (144)	3048 (120)	1



Al-Barrak Group Company for Trade, Industry and Contracting Branch

Factory - Al-Ahsa Industrial City 2257021648

Administration - Al-Ahsa 31982 - Mubarraz PO Box 10170

Tel: 9665866406 – 9665826507 - 966135828509

Fax: 96635870212

barrakgdf@gmail.com

مجموعة البراك للتجارة والصناعة و المقاولات
المصنع - المدينة الصناعية بالأحساء ٢٢٥٧.٢١٦٤٨
الإدارة - الأحساء ٣١٩٨٢ - المبرز ص.ب. ١.١٧.
تليفون: ٩٦٦٥٨٢٨٥.٩ - ٩٦٦٥٨٢٦٥.٧ - ٩٦٦٥٨٦٦٤.٦
فاكس: ٩٦٦٣٥٨٧.٢١٢